

Prilog 8

Živčić, Juraj

Supplement / Prilog

Publication year / Godina izdavanja: **2016**

Permanent link / Trajna poveznica: <https://urn.nsk.hr/urn:nbn:hr:128:095285>

Rights / Prava: [In copyright](#) / [Zaštićeno autorskim pravom](#).


Download date / Datum preuzimanja: **2024-07-10**



VELEUČILIŠTE U KARLOVCU
Karlovac University of Applied Sciences

Repository / Repozitorij:

[Repository of Karlovac University of Applied
Sciences - Institutional Repository](#)



VISKOTA1
VISKOTA2


SPRINKLER BAZEN
visina vode 1,8 m

VISKOTA1
VISKOTA2

P.13
sprinkler st.
P=17,81m²
beton

SV
T90



NAPOMENA:
KOD BETONIRANJA SPREMNIKA POTREBNO JE JEDINO OSTAVITI OTVOR ZA ULAZ
U SPREMNIK DOK CE SE SVI OSTALI PRODORI U SPREMNIK NAKNADNO BUŠITI.







9. ZASUN
10. ALARM-STOP SLAVINA
11. VENTIL ZA PRAŽNENJE
13. MANOMETAR (TLAK ISPRED SPRINKLER VENTILA)
14. DRENAŽNI VENTIL
15. VENTIL ZA PUNJENJE ZRAKOM CJEVNE MREŽE
16. MANOMETAR (TLAK ZRAKA U CJEVNOJ MREŽI)
17. VENTIL ZA PUNJENJE UBRZIVAČA ZRAKOM

1. ZASUN
2. ALARM-STOP SLAVINA
3. VENTIL ZA PRAŽNENJE
4. VENTIL ZA PROBU
5. MANOMETAR (TLAK ISPRED SPRINKLER VENTILA)
6. MANOMETAR (TLAK U SPRINKLER CJEVNOJ MREŽI)
7. DRENAŽNI VENTIL
8. SLAVINA MANOMETRA

- LEGENDA:
1 - Glavna sprinkler pumpa KSB Etanorm MX 65-200, 30kW
2 - Rezervna sprinkler pumpa KSB Etanorm MX 65-200, 30kW
3 - Sprinkler ventil "MOKRI" NO150
4 - Sprinkler ventil "SUHI" NO80
5 - Nepovratna klapna NO150 - prema V.V.
6 - Zasun NO150 sa el. kontrolom otvorenosti prema V.V.
7 - Nepovratna klapna NO150
8 - Zasun NO150
9 - Jockey pumpa
10 - Mjerač protoka NO100
11 - Zasun NO100 od probe pumpe
12 - Sprinkler alarmno zvono
13 - Centrala za nadzor sprinkler instalacije
14 - Elektroormar od glavne sprinkler pumpe i Jockey pumpe
15 - Elektroormar od rezervne sprinkler pumpe
16 - Kuglasti ventil NO50 sa el. kontrolom otvorenosti - by-pass V.V.
17 - Betonsko korito h=50cm
18 - Ispust u kanalizaciju
19 - Kompresor
20 - Usisna košara sa protivtložnom pločom NO150
21 - Usisna košara NO32
22 - Nepovratna klapna NO100
23 - Manometar
24 - Vakuumetar



SPRINKLER d.o.o.		Voćarska cesta 112, Zagreb tel: 01 6395 364, fax: 01 6431 481 e-mail: sprinkler@sprinkler.hr OIB: 97668348645		Datum: 11.2014.			
Investitor:	MEGALIT d.o.o. Kralja Zvonimira 14, Solin OIB: 87219083598	Glavni projektant:	Nikica Tabain, dipl.ing.arh.	  			
Strukovna odrednica:	SPRINKLER INSTALACIJA	Projektant:	Branimir Samac dipl.ing.stroj.				
Gradevina:	ZAMJENSKA GRAĐEVINA – TRGOVAČKI CENTAR	Suradnici:	Branimir Čeh dipl.ing.stroj. Hrvoje Lovko dipl.ing.stroj.	Hrvatska komora inženjera strojarstva Branimir Samac dipl. ing.stroj. Ovlašteni inženjer strojarstva  S 1097			
Loakcija:	Ul. kardinala Alojzija Stepinca, Trogir, k.č. 3641, 3644, 3647, 3662, 3663, 3664, 3668/1, 3670, 3671, 3672/1, 3673, k.o. Trogir	Mapa br.:	7		Zop:	A-359-14	Mjerilo:
Sadržaj:	DISPOZICIJA SPRINKLER INSTALACIJE SPRINKLER STANICA	Faza:	Glavni projekt	Broj projekta:	418-14	Nacr. br.:	09