

## Prilog 7

---

Živčić, Juraj

### Supplement / Prilog

Publication year / Godina izdavanja: **2016**

Permanent link / Trajna poveznica: <https://urn.nsk.hr/urn:nbn:hr:128:012108>

Rights / Prava: [In copyright](#) / [Zaštićeno autorskim pravom](#).

Download date / Datum preuzimanja: **2024-12-27**




**VELEUČILIŠTE U KARLOVCU**  
Karlovac University of Applied Sciences


Repository / Repozitorij:

[Repository of Karlovac University of Applied  
Sciences - Institutional Repository](#)






Detalj 1 Priključak za sprinkler




MATERIJALNI SMJER IZ OBLASTI A	
oznaka	opis
T001	DN50
T002	DN50
T003	DN50
T004	DN50
T005	DN50
T006	DN50
T007	DN50
T008	DN50
T009	DN50
T010	DN50
T011	DN50
T012	DN50
T013	DN50
T014	DN50
T015	DN50
T016	DN50
T017	DN50
T018	DN50
T019	DN50
T020	DN50


Detalj 2 Detalj uređaja sprinkler visoke mlaznice




Detalj 3 Sprinkler mlaznična stropična



Detalj 4 Detalj uređaja sprinkler visoke mlaznice



Detalj 5 Detalj montaže mlaznice i sprinkler u stropu



### LEGENDA

- SPRINKLER MLAZNIČNA VISEĆA S IZVEŠTOM K=80 89°C
- SPRINKLER MLAZNIČNA STROPIČNA K=80 89°C
- SPRINKLER MLAZNIČNA VISEĆA K=80 89°C (STROPIČNA (unutar stropnog stropa) K=80 89°C
- SPRINKLER MLAZNIČNA VISEĆA SA IMA HTS K= 80 89°C (STROPIČNA (unutar stropnog stropa) K=80 89°C
- SPRINKLER MLAZNIČNA VISEĆA I STROPIČNA (unutar stropnog stropa) K=80 89°C
- SPRINKLER MLAZNIČNA STROPIČNA K= 80 89°C
- SPRINKLER MLAZNIČNA STROPIČNA K= 80 89°C
- SPRINKLER ZA OPŠTI KONKURATNAZ SINEF INSTALACIJE

**SPRINKLER d.o.o.**

MESALIT d.o.o. 14. Sedin  
 Križevci  
 OIB: 6721983559

ZAMJENSKA GRADJEVINA - TROSOVAČKI CENTAR  
 UL. Bartulina, Mladost Srebren, Trogir

11.2014.

7 A-359-14  
 418-14